

FEDERAL EMERGENCY MANAGEMENT AGENCY
NATIONAL FLOOD INSURANCE PROGRAM

FLOODPROOFING CERTIFICATE
FOR NON-RESIDENTIAL STRUCTURES

The floodproofing of non-residential buildings may be permitted as an alternative to elevating to or above the Base Flood Elevation; however, a floodproofing design certification is required. This form is to be used for that certification. Floodproofing of a residential building does not alter a community's floodplain management elevation requirements or affect the insurance rating unless the community has been issued an exception by FEMA to allow floodproofed residential basements. The permitting of a floodproofed residential basement requires a separate certification specifying that the design complies with the local floodplain management ordinance.

BUILDING OWNER'S NAME
CITY OF ALBANY, PARKS & REC. DEPT.
STREET ADDRESS (Including Apt., Unit, Suite, and/or Bldg. Number) OR P.O. ROUTE AND BOX NUMBER

FOR INSURANCE COMPANY USE	
POLICY NUMBER	
COMPANY NAIC NUMBER	

OTHER DESCRIPTION (Lot and Block Numbers, etc.)
MONTEITH RIVER PARK (TAX MAP 114W-1DD T¹⁰² 200)
CITY ALBANY STATE OREGON ZIP CODE 97321
11504W01000200

SECTION I FLOOD INSURANCE RATE MAP (FIRM) INFORMATION

Provide the following from the proper FIRM:

COMMUNITY NUMBER	PANEL NUMBER	SUFFIX	DATE OF FIRM INDEX	FIRM ZONE	BASE FLOOD ELEVATION (In AO Zones, Use Depth)
<u>410137</u>	<u>0003</u>	<u>F</u>	<u>JULY 7, 1999</u>	<u>AE</u>	<u>202.3</u>

SECTION II FLOODPROOFING INFORMATION (By a Registered Professional Engineer or Architect)

Floodproofing Design Elevation Information:

Building is floodproofed to an elevation of 196.33 feet NGVD. (Elevation datum used must be the same as that on the FIRM.)

Height of floodproofing on the building above the lowest adjacent grade is 7 feet.

(NOTE: for insurance rating purposes, the building's floodproofed design elevation must be at least one foot above the Base Flood Elevation to receive rating credit. If the building is floodproofed only to the Base Flood Elevation, then the building's insurance rating will result in a higher premium.) SEE ATTACHMENT 'A'

SECTION III CERTIFICATION (By Registered Professional Engineer or Architect)

Non-Residential Floodproofed Construction Certification:

I certify that, based upon development and/or review of structural design, specifications, and plans for construction, the design and methods of construction are in accordance with accepted standards of practice for meeting the following provisions:


JDM The structure, together with attendant utilities and sanitary facilities, is watertight to the floodproofed design elevation indicated above, with walls that are substantially impervious to the passage of water. SEE ATTACHMENT 'A'

All structural components are capable of resisting hydrostatic and hydrodynamic flood forces, including the effects of buoyancy, and anticipated debris impact forces.

I certify that the information on this certificate represents my best efforts to interpret the data available. I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

CERTIFIER'S NAME <u>JOHN D. MCGEE</u>	LICENSE NUMBER (or Affix Seal) <u>58902</u>
TITLE <u>CIVIL ENGINEER</u>	COMPANY NAME <u>K4 ENGINEERING, INC.</u>
ADDRESS <u>PO BOX 725</u>	CITY <u>ALBANY</u>
SIGNATURE <u>JDM</u>	STATE <u>OR</u>
	ZIP CODE <u>97321</u>
	DATE <u>7/27/01</u>
	PHONE <u>(541) 928-2583</u>

Copies should be made of this Certificate for: 1) community official, 2) insurance agent/company, and 3) building owner.



Attachment "A"

(FLOODPROOFING CERTIFICATE FOR NON-RESIDENTIAL STRUCTURES)

Flood Design Elevation Information:

The top of the stage structure is at elevation 196.33 feet by design. The top of the structure is below the Base Flood Elevation (BFE) by design.

Non-Residential Floodproofed Construction Certification:

The structure is designed to allow water to flow through. All construction components were selected for their ability to resist effects of submersion.



RENEWAL DATE 12/31/02